

# ERRATA

## Guidance Note 3

**March 2015**

Page 121, Table A4

Please note, Table A4 contained inaccurate values.

For 0.1 to 5 second disconnection times (includes 0.4 second disconnection time)

Circuit-breaker type	Circuit-breaker rating (amperes)														
	3	5	6	10	15	16	20	25	30	32	40	45	50	63	100
1	15.5	8.8	7.73	4.4	2.93	2.76	2.2	1.76	1.47	1.38	1.1	0.98	0.88	0.7	0.44
1 new	14.56	8.74	7.28												
2	8.4	5.0	4.2	2.5	1.67	1.58	1.25	1.0	0.83	0.79	0.63	0.56	0.5	0.4	0.25
B	11.74	7.0	5.87	3.5	2.3	2.2	1.75	1.4	1.17	1.1	0.88	0.78	0.7	0.56	0.35
B new	11.65														
3&C	3.52	2.93	1.76	1.47	0.98	1.1	0.74	0.59	0.49	0.55	0.37	0.33	0.29	0.27	1.17
3&C new	5.82	3.49	2.91	1.75	1.16	1.09	0.87	0.7	0.58		0.44	0.38	0.35		0.17

The corrected table is provided below for insertion into your book.

For 0.1 to 5 second disconnection times (includes 0.4 second disconnection time)

Circuit-breaker type	Circuit-breaker rating (amperes)														
	3	5	6	10	15	16	20	25	30	32	40	45	50	63	100
1	14.56	8.74	7.28	4.4	2.93	2.76	2.2	1.76	1.47	1.38	1.1	0.98	0.88	0.7	0.44
2	8.4	5.0	4.2	2.5	1.67	1.58	1.25	1.0	0.83	0.79	0.63	0.56	0.5	0.4	0.25
B	11.65	7.0	5.87	3.5	2.3	2.2	1.75	1.4	1.17	1.1	0.88	0.78	0.7	0.56	0.35
3&C	5.82	3.49	2.91	1.75	1.16	1.09	0.87	0.7	0.58	0.55	0.44	0.38	0.35	0.27	0.17